Technical Bulletin.



REWIRING OF THE AIRBLOC ACT LOW VOLTAGE RELAYS.



INDEX Section

General information	1
Tools and parts requirement	2
Step by step instruction	3

WARNINGS

All installations should be in accordance with the relevant requirements of Building Regulations, Local Authority Byelaws and I.E.E. Regulations and Units should be wired by a competent, qualified Electrician.

Tools required.

The following tools and equipment will be required to complete this task:

- 1. Rewiring kit pt no 900365 (as a retrofit for the ORIGINAL configuration).
- 2. Rewiring kit pt no 900366 (as a retrofit for the MODIFIED configuration).
- Electrical screwdriver.
- 4. Small pozi screwriver.

General Information.

Where re-wiring of the ACT low voltage relays are required, the following instructions will need to be carried out.

The information contained in this technical bulletin is designed to aid a qualified or competent service technician in the instruction it is in-

tended for.

There are two versions of the options currently out in the field. The following pages will be split into two halves. Note your particular Airbloc ceiling tile type and follow the instructions to suit





The original configuration consisted of a wiring 'tray' attached to the front of the wiring contractors terminal enclosure. This houses a 24V relay and base, a 24V relay and a 5 way terminal block (see fig.2 below).



fig.2 original contractors box configuration

This type is identified by it's four wiring spade connectors, connected to the clear relay.



The second configuration houses a 24V relay and base, a 24V relay and a 5 way terminal block within the contractors terminal enclosure box itself (see fig.3 below).



fig.3 Modified wiring tray configuration

This type is identified by it's two wiring spade connectors & two BLUE wiring spade connectors, connected to the clear relay.



Step by step instructions.



Warning
Ensure electrical power is isolated from the product.

For the details relating to the wiring tray configuration, follow the details shown on the LEFT HAND side.

For ease of maintenance it may be advisable to firstly remove the ceiling tile. For information on how this is achieved, please refer to the Installation instruction manual.




1. Using a small pozi screwdriver, remove the THREE screws. Retain for later.

For the details relating to the contractors terminal box configuration, follow the details shown on the RIGHT HAND side.


For ease of maintenance it may be advisable to firstly remove the ceiling tile. For information on how this is achieved, please refer to the Installation instruction manual.




1. Using a small pozi screwdriver, remove the FOUR screws. Retain for later.




2. Remove the terminal connectors from the **CLEAR RELAY** as shown in the photo.



3. Remove the RED cable from BLACK RE-LAY n.o. terminal 14




4. Remove the two RED cables from **termi- nal 2**




5. Remove the **BLACK** cable from **BLACK RELAY COIL terminal A2**


For the details relating to the contractors terminal box configuration, follow the details shown on the **RIGHT HAND** side.




2. Remove the terminal connectors from the relay as shown in the photo above




3. Remove the **BROWN** cable from **BLACK RELAY com. terminal 11**




4. Remove the RED and BROWN cables from terminal L1




5. Remove the **BROWN** cable from **BLACK RELAY n.o. terminal 14**



Remove the two BLACK cable from terminal 5



7. Remove the RED cable from terminal 4




8. Remove the RED cable from BLACK RE-LAY COIL terminal A1



9. Remove the **RED** cable from **terminal 3**

For the details relating to the contractors terminal box configuration, follow the details shown on the **RIGHT HAND** side.




6. Remove the **BROWN** cable from **terminal** 5



7. Remove the RED cable from terminal H1



8. Remove the **TWO GREY** cables from **BLACK RELAY terminal A2**




9. Remove the GREY cable from **terminal 02**



10. Remove the RED cable from terminal L



11. Pull the **RED** cable through the sleeving and dispose.



12. Remove the CLEAR RELAY by first removing the self tapping screw, then loosening the screw on the opposite side (see above). Replace using a new CLEAR RELAY and position using the same two screws (see below).



For the details relating to the contractors terminal box configuration, follow the details shown on the **RIGHT HAND** side.



10. Remove the RED cable from terminal 01



11. Remove the CLEAR RELAY by first removing the self tapping screw (see above), then withdrawing the relay (see below). Replace using a new CLEAR RELAY and position using the same screw.





 Locate the rewiring kit of cables. Using the short GREY cable, push the spade connector onto bottom right hand CLEAR RE-LAY terminal no. A2



 Locate the rewiring kit of cables. Using the short RED cable, push the spade connector onto bottom left hand CLEAR RE-LAY terminal no. A1



14. Position and tighten other RED cable end into **terminal 4**



15. Locate twin **BLACK** wire. Position **boot-** lace into terminal 5 and tighten



 Push the spade connector onto bottom right hand CLEAR RELAY terminal no. A2 For the details relating to the contractors terminal box configuration, follow the details shown on the **RIGHT HAND** side.



 Position and tighten other cable end into the BLACK RELAY terminal A2 TO-GETHER WITH the long GREY cable.



14. Position and tighten other GREY cable end into **terminal 02**



15. Using the *THIN* RED cable, push the spade connector onto bottom left hand CLEAR RELAY terminal no. A1



16. Position and tighten other RED cable end into **terminal 01**




 Position and tighten other cable end into BLACK RELAY terminal A2



18. Feed the **LONG RED** cable through the sleeving-bootlace first



Position and tighten cable end into terminal block terminal L



20. Push the spade connector onto top left hand CLEAR RELAY terminal no. 21


For the details relating to the contractors terminal box configuration, follow the details shown on the **RIGHT HAND** side.



17. Using the *THICK* RED cable, push the spade connector onto bottom left hand CLEAR RELAY terminal no. 22




18. Position and tighten other **THICK RED** cable end into **terminal H1**



19. Locate twin **RED** & **BLACK** wire. Position **bootlace** into **terminal L1** and tighten



20. Push the spade connector onto top left hand CLEAR RELAY terminal no. 21



21. Locate twin **RED** wire. Position **bootlace** into **terminal 2** and tighten



22. Push the spade connector onto top right hand CLEAR RELAY terminal no. 22



- Position and tighten other RED cable end into BLACK RELAY terminal 14
- 24. Carefully replace orange relay if removed
- 25. Check all cables for tightness.
- 26. Replace cover
- 27. Re-install ceiling tile (if removed)
- 28. Re-instate power and check for operation

For the details relating to the contractors terminal box configuration, follow the details shown on the **RIGHT HAND** side



21. Position and tighten other **BROWN** cable from **BLACK RELAY n.o. terminal 11**



22. Locate single **BROWN** wire. Position **bootlace** into **terminal F** and tighten



- 23. Position and tighten other **BROWN** cable end into **BLACK RELAY terminal 14**
- 24. Carefully replace orange relay if removed
- 25. Check all cables for tightness.
- 26. Replace cover
- 27. Re-install ceiling tile (if removed)
- 28. Re-instate power and check for operation









Brierley Hill West Midlands
DY5 1QA United Kingdom
Telephone 01384 489700
Facsimile 01384 489707
UK sales email sales@ambirad.co.uk
Website www.ambirad.co.uk
Database http://support.ambirad.co.uk

Ambi-Rad Limited Fens Pool Avenue

AIRBLOC is the registered Trademark of Ambi-Rad Limited.

Due to continuous product innovation, Ambi-Rad reserves the right to change product specification without due notice.



